

Belt Press Filter Isolation Checklist

Step	Action	Complete
1	Isolate Power at FL4-60B Drive	
2	Isolate Power at FN4-64B Drive	
3	Secure Cloth Water Flow Valve	
4	Set HBF Feed Pump B to Manual	
5	Close HBF-B Fresh Water Isolator	